

515 VALVE WITH SA ACTUATOR

FEATURES

The 515+SA ball valve is designed for automatic opening/closing of unloaded industrial fluid lines up to a pressure of 20 bar. The API 6D, split-body, full-bore 515 valve is CE, ATEX, fire safety, SIL, and ISO 15848-1 approved for fugitive emissions. Dimensions are standardized to ANSI B16.10. The ISO 5211 plate enables direct mounting of the SA actuator. It is perfectly suited to industrial use, both indoors and outdoors.


AVAILABLE MODELS

515 AIT: carbon steel body DN15 to 65.

515 IIT: stainless steel body DN15 to 65.

ANSI 150 flange connection.

Voltages: 12 V DC, 24 V AC-DC, and 230 V AC.



SA



SA-X 05
SA-X 09




with SA-X 05
with SA-X 09



LIMITS OF USE

Max. allowable pressure (PS)	20 bar (20°C)
Min./max. allowable temperature (TS)	<u>Steel</u> : -29°C/+230°C <u>St steel</u> : -50°C/+230°C
Room temperature	- 20°C /+70°C
Duty cycle	<u>S2</u> : 15mn - <u>S4</u> : 50% (SA 03 / SA 05)
	<u>S2</u> : 15mn - <u>S4</u> : 30% (SA 09)



Information given as an indication only and subject to possible modifications


	SECTORIEL S.A. 45 rue du Ruisseau 38290 SAINT QUENTIN-FALLAVIER – FRANCE Tél : +33 4 74 94 90 70 - Fax : +33 4 74 94 13 95 www.sectoriel.com / Email : sectoriel@sectoriel.fr	Pages	1/4
		Ref.	TDS515+SA
		Rev.	03
		Date	12/2025

515 VALVE WITH SA ACTUATOR

DIRECTIVES AND MANUFACTURING STANDARDS

OBJECT	Standard	NB	OBJECT	Standard
Directive PED 2014/68	DN 15 et 20: excluded		Valve testing	API 598
	DN 25 and 65: Category III	BV 0062	Material certificate	EN 10204
Design	API 6D		Alloy grade	EN 1503-2
Dimensions	ANSI B16.34		Corrosion resistance	NACE MR 01.75
Flange dimensions	ANSI B16.5		Fugitive emissions	EN 15848-1
Fire safe	BS 6755, API 6FA, ISO 10497		Level SIL 3 (valve only)	EN 61508
Motorization connection	ISO 5211		Actuator	EN 15714-2
ATEX Directive 14/34	Valve		II 2G/D Tx areas 1,2, 21 and 22	
	Actuator (option SA-X)	KEMA 0344	II 2G EEx d II B T4 for areas 1 and 2	

CONSTRUCTION




N°	Item	515 AIT steel	515 IIT SS	N°	Item	515 AIT steel	515 IIT SS
1	Body	A216 WCB	A351 CF8M	14	End Stop	Carbon steel	St steel
2	Ends	A216 WCB	A351 CF8M	15	Body bolt	DIN 933 A4-70	
3	Ball	A 351 Gr. CF8M		16	Handle screw	DIN 933 A4-70	
4	Stem	St steel A 479 Tp.316		17	Washer	Galvanised steel	AISI 304
5	Seat	PTFE		18	Thrust washer	PTFE+25% GF	
6	Lever	Nodular cast iron		19	Antistatic device	St steel	
8	Belleville washer	Steel	Steel ENP	28	Nut	A194 Gr 7	A194 Gr 8M
9	Stop plate	Steel	St steel 304	39	Stem bushing	PTFE+25% GF	
10	Valve spacer	AISI 303	AISI 316	41	Spacer	Carbon steel	AISI 304
11	Gland packing	Graphite		46	Washer	AISI 304	
12	Antifriction ring	PTFE+25% GF		72	O ring	FKM	
13	O ring	St steel 316L + PTFE + graphite		89	ID plate	St steel	

Information given as an indication only and subject to possible modifications

	SECTORIEL S.A. 45 rue du Ruisseau 38290 SAINT QUENTIN-FALLAVIER – FRANCE Tél : +33 4 74 94 90 70 - Fax : +33 4 74 94 13 95 www.sectoriel.com / Email : sectoriel@sectoriel.fr	Pages	2/4
		Ref.	TDS515+SA
		Rev.	03
		Date	12/2025

515 VALVE WITH SA ACTUATOR

DIMENSIONS (mm) and WEIGHT (kg)



DN	15	20	25	40	50	65
ΦP	15	20	25	40	50	65
L	108	117	127	165	178	190
L1	47	50	52	65	61	75
ΦR	60.3	69.9	79.4	98.4	120.7	139.7
n x Φ S	4x15.9	4x15.9	4x15.9	4x15.9	4x19	4x19
Φ T	90	100	110	125	150	180
H	110	117	129	148	155	169
M	164	164	164	213	213	348
ISO	F05	F05	F05	F07	F07	F07
B	11,2	13,2	22,7	41,5	41,5	44
C	5,7	9,2	10,2	19,2	19,2	19.7
I	M12	M12	M12	M18	M18	M22
J	9	9	9	13	13	16
Weight	2	3	3,5	8	11	16

FLOW RATE Kv (m³/h)

DN	15	20	25	40	50	65
Kv	20	40	75	170	270	550

VALVE SEAT OPTIONS

Sealing	PTFE	PTFE + fiberglass	PTFE + graphite	PTFE+st steel
TS	-20°C/+230°C	-20°C/+230°C	-20°C/+260°C	-20°C/+260°C
Code	515AIT or IIT	515AIGF or IICG	515AICG or IICG	515AIS or IIS

Information given as an indication only and subject to possible modifications

	SECTORIEL S.A. 45 rue du Ruisseau 38290 SAINT QUENTIN-FALLAVIER – FRANCE Tél : +33 4 74 94 90 70 - Fax : +33 4 74 94 13 95 www.sectoriel.com / Email : sectoriel@sectoriel.fr	Pages	3/4
		Ref.	TDS515+SA
		Rev.	03
		Date	12/2025

515 VALVE WITH SA ACTUATOR

SA ELECTRICAL MOTORIZATION

Suggested standard SA actuator under the following conditions:

- Electric actuator with an IP 67 epoxy-coated aluminium enclosure and steel gears
- A minimum 1.3 safety factor compared with the valve nominal torque rating
- A maximum pressure differential up/downstream of 10 bar (=ΔP)
- Electric actuator mounted with stainless steel bracket and coupler according to the EN 15081 standard

DN	Actuator	Power	Intensity 230V CA	Intensity 24V CA-CC	Operating Time*	Standard equipment of the actuator
15	SA 03/SA 05	18 / 6W	0,1 / 0,23 A	0,8 / 1,8 A	12/17 s	2 adjustable limit switches. 2 dry auxiliary switches. 5W anti-condensation heater. Actuator thermal cut-out. Manual override by key. Backlit position indicator (except for SA-X). Electrical connection: 2 gland packs M20x1.5
20	SA 03/SA 05	18 / 6W	0,1 / 0,23 A	0,8 / 1,8 A	12/17 s	
25	SA 03/SA 05	18 / 6W	0,1 / 0,23 A	0,8 / 1,8 A	12/17 s	
40	SA 05	6W	0,23 A	1,8 A	17 s	
50	SA 09	6W	0,25 A	2,1 A	32 s	
65	SA 09	6W	0,25 A	2,1 A	32 s	
40 to 200	See to 515 + NA					

*Unloaded operating time is given for information purposes only. It may vary depending on the medium
For any other working conditions, please contact us

ACTUATOR OPTIONS

There are many different options. Please contact our commercial department.

1	2	3	4	5
SA 05 S: Slow closing electric actuator 70 s	SA 05 PCU: Regulation actuator 4-20 mA or 0-10 V	SA 05 SCP: supercapacitor safety actuator	SA 05 X: Actuator for use in ATEX areas 1 and 2	SR 05: Safety spring return actuator
				
6	SAPUI electric actuator with a feedback potentiometer			
7	Electric actuator sized for a maximum pressure differential up/downstream over 10 bar (=ΔP)			
8	NA electric actuator with a declutchable manual override by handwheel			


ATEX AREAS INSTALLATION

It is compulsory to specify if the installation of the automatic valve 515+SA-X will take place in ATEX areas 1 or 2 while making the order. Our services will proceed to the mounting check and a grounding strip installation and edit a mounting certificate. Those operations are performed by our proper engineers. Please contact us for further details. It is also compulsory to follow the ATEX area mounting and maintenance special instructions for motorized valves. The ATEX gland packs and sealing plugs are not provided. Please use the following codes:

ATEX aluminium gland pack M20x1.5	Code 980179	Bouchon aluminium M20x1,5 ATEX	Code 980180
-----------------------------------	-------------	--------------------------------	-------------

Information given as an indication only and subject to possible modifications



	SECTORIEL S.A. 45 rue du Ruisseau 38290 SAINT QUENTIN-FALLAVIER – FRANCE Tél : +33 4 74 94 90 70 - Fax : +33 4 74 94 13 95 www.sectoriel.com / Email : sectoriel@sectoriel.fr	Pages	4/4
		Ref.	TDS515+SA
		Rev.	03
		Date	12/2025



DN	15	20	25
SERVO	SA03	SA03	SA03
A	108	117	127
B	237.5	244.5	249.5
C	117	117	117
D	113	113	113
E	131.5	131.5	131.5
POIDS KG	4.2	5.2	5.7

Informations données à titre indicatif et sous réserve de modifications éventuelles

Ech: /	Date :08/03/2018	Dessiné par : E.D.	Tolérances générales : +/- 0.2	Modifications	Date	REV.
ROBINET A TOURNANT SHERIQUE 515JC/BALL VALVE 515JC + SERVOMOTEUR SA03/ELECTRICAL ACTUATOR SA03				Matière :		
				Poids (Kg) :		
				Traitement : SANS		
				45, Rue du Ruisseau		
				38297 SAINT QUENTIN FALLAVIER		
				Plan n° Ens 1321		



DN	15	20	25	40
SERVO	SA05X	SA05X	SA05X	SA05-SA05X
A	108	117	127	165
B	-	-	-	289
B(SAX)	306	312	317	335
C	127	127	127	127
D	170	170	170	170
E	-	-	-	153
E(SAX)	199	199	199	199
G	100	100	100	100
POIDS KG	-	-	-	12
POIDS(SAX) KG	7,5	8,5	9	13,7

Informations données à titre indicatif et sous réserve de modifications éventuelles

Ech: /	Date :08/03/2018	Dessiné par : E.D.	Tolérances générales : +/- 0.2	Modifications	Date	REV.
ROBINET A TOURNANT SHERIQUE 515JC/BALL VALVE 515JC + SERVOMOTEUR SA05-SAX05/ELECTRICAL ACTUATOR SA05-SAX05				Matière :		
				Poids (Kg) :		
				Traitement : SANS		
				45, Rue du Ruisseau		
				38297 SAINT QUENTIN FALLAVIER		
				Plan n° Ens 1322		

SA 03 ELECTRIC ACTUATOR

FEATURES

The SA03 electric actuator is intended for motorising under on/off operation the 1/4 turn valves with a torque of at most 30 Nm. With a compact construction and epoxy-coated aluminium housing, it is especially well suited for motorising small diameter ball valves. Backlit dome position indicator. IP67 leak-tightness: it can be used both indoors and outdoors. Compliant with the EN 15714-2 standard.

AVAILABLE MODELS

Supply voltages: 230V AC and 24V AC/DC

LIMITS OF USE



IP Code	IP 67
Ambient temperature	- 20°C / + 70°C
Service factor	<u>S2</u> : 15 minutes / <u>S4</u> : 50%

MECHANICAL FEATURES

Gear box	treated steel pinions	
Torque	30 Nm	
Angle of rotation	90° +/- 5°	
Manoeuvring time	24V AC/DC	230V AC
	<u>AC</u> : 9 s / <u>DC</u> : 7 s	12 s
ISO 5211	F03 / F05 star 11	
Declutching	key-controlled	
Override control	using a 6 mm hex key	
Weight	1.5 kg	

ELECTRICAL FEATURES

Power	18 W	
Current	24V AC/DC	230V AC
	0.8 A	0.1 A
Motor protection	thermal	
Limit switches	2 adjustable switches	
Auxiliary switches	2 adjustable dry switches 250V AC 5A	
Anti-condensation	2x1.5W heater	
Electrical connection	2 x M20 x 1.5 (one PE and one plug provided)	



Information given as an indication only, and subject to possible modifications




SECTORIEL S.A.
45 rue du Ruisseau
38290 SAINT QUENTIN-FALLAVIER – FRANCE
Telephone: +33 4 74 94 90 70 - Fax: +33 4 74 94 13 95
www.sectoriel.com / Email: sectoriel@sectoriel.fr

Pages	1/5
Ref.	FT23000 ENG
Rev.	06
Date	05/2023

SA 03 ELECTRIC ACTUATOR


DIMENSIONS (mm)



CONSTRUCTION

No.	Item	Material
1	Housing	Epoxy-coated aluminium alloy
2	Cover	Epoxy-coated aluminium alloy
3	Cover screw	Stainless steel
4	Dome	polycarbonate

ASSEMBLY POSITIONS



Information given as an indication only, and subject to possible modifications

	SECTORIEL S.A. 45 rue du Ruisseau 38290 SAINT QUENTIN-FALLAVIER – FRANCE Telephone: +33 4 74 94 90 70 - Fax: +33 4 74 94 13 95 www.sectoriel.com / Email: sectoriel@sectoriel.fr	Pages	2/5
		Ref.	FT23000 ENG
		Rev.	06
		Date	05/2023

SA 03 ELECTRIC ACTUATOR

GUARANTEE

Before any contact with our services, identify the type of actuator.

SECTORIEL actuators have a 12-month guarantee from the delivery date. The parts admitted as faulty by an assessment at our facility will be replaced at our expense. Complaints generated by incorrect use or a modification of the actuator, cannot be taken into account.

VERIFICATIONS AND ACCEPTANCE

At acceptance, check that:

- the packaging is in good condition,
- the actuator is as ordered,
- the equipment is not damaged.

It is recommended to install the actuator as soon as accepted and not to leave it unused. If the equipment has to be stored, it must be in a dry place protected from weather.

PRECAUTIONS FOR OPERATION

Before installing, make sure that the installation is completely depressurized and brought to ambient temperature.

Do not install this actuator in a zone classified as explosive (ATEX).

The IP Code of the actuator is IP67 for interior or exterior mounting. Do not install this actuator in a marine environment and do not immerse it.

The actuator must not be powered during installation and maintenance of the valve on the pipework, and of the actuator on the valve.

Before proceeding to the electrical connection, check the supply voltage of the actuator.

Do not mount the actuator in series or in parallel with other electrical motors. If need be, use relays.

Do not mount the actuator on valves with higher torque than the nominal torque of the actuator.

INSTALLATION AND OPERATION

Install the actuator on the valve (already done for the units assembled in our workshops)

Perform the electrical wiring as shown on the diagram below

Adjust the switch stops (already done for the units assembled in our workshops).

View the movement of the valve using the indicator light on the cover.

SA03 actuator: to use the manual override, first disconnect the electrical power, then turn the hollow hex-head screw with a hex key.




Reposition the manual override after use.

Information given as an indication only, and subject to possible modifications


	SECTORIEL S.A. 45 rue du Ruisseau 38290 SAINT QUENTIN-FALLAVIER – FRANCE Telephone: +33 4 74 94 90 70 - Fax: +33 4 74 94 13 95 www.sectoriel.com / Email: sectoriel@sectoriel.fr	Pages	3/5
		Ref.	FT23000 ENG
		Rev.	06
		Date	05/2023

SA 03 ELECTRIC ACTUATOR

SWITCH SETTING

1. Switch the actuator to manual mode	2. Turn the key to bring the valve, successively, in the open and closed positions, and to set the switches as shown below.							
 Auto Manual								
	The cams are attached to the drive stem							
	Clockwise rotation = valve closing. The micro-switch stops the actuator.							
	Anti-clockwise rotation = valve opening. The micro-switch stops the actuator.							
	<table border="1"> <tr> <td>CLS</td><td>Closing switch</td></tr> <tr> <td>OLS</td><td>Opening switch</td></tr> <tr> <td>ACSL</td><td>Auxiliary closing switch</td></tr> <tr> <td>OCSL</td><td>Auxiliary opening switch</td></tr> </table>	CLS	Closing switch	OLS	Opening switch	ACSL	Auxiliary closing switch	OCSL
CLS	Closing switch							
OLS	Opening switch							
ACSL	Auxiliary closing switch							
OCSL	Auxiliary opening switch							

SETTING THE POSITION INDICATOR

 Dome Indicator Screw	The position of the valve is indicated by the indicator. If its alignment is incorrect, remove the cover and proceed to its setting by unscrewing the attachment screw.
--	--


Information given as an indication only, and subject to possible modifications

	SECTORIEL S.A. 45 rue du Ruisseau 38290 SAINT QUENTIN-FALLAVIER – FRANCE Telephone: +33 4 74 94 90 70 - Fax: +33 4 74 94 13 95 www.sectoriel.com / Email: sectoriel@sectoriel.fr	Pages	4/5
		Ref.	FT23000 ENG
		Rev.	06
		Date	05/2023


SA 03 ELECTRIC ACTUATOR

ELECTRICAL WIRING

Wiring for 110/230V AC voltages



Wiring for 24V AC/DC voltages



Information given as an indication only, and subject to possible modifications

	SECTORIEL S.A. 45 rue du Ruisseau 38290 SAINT QUENTIN-FALLAVIER – FRANCE Telephone: +33 4 74 94 90 70 - Fax: +33 4 74 94 13 95 www.sectoriel.com / Email: sectoriel@sectoriel.fr	Pages	5/5
		Ref.	FT23000 ENG
		Rev.	06
		Date	05/2023

SA 05 - SA 09 ELECTRIC ACTUATOR

FEATURES

The SA 05 / SA 09 electric actuator are intended for motorising industrial 1/4 turn valves. The torques are 50 Nm and 90 Nm. With a compact, robust construction and IP67 epoxy-coated aluminium housing, the SA actuator is especially well suited for motorising ball valves and butterfly valves installed in workshops or outdoors. The SA has a manual key control and a 3D visual position indicator. Compliant with the EN 15714-2 standard.

AVAILABLE MODELS

Supply voltages: 230 Vac (50-60Hz), 24 Vac/dc and 12 Vdc.

Options: 110 Vac, feedback potentiometer, local command.



LIMITS OF USE

IP rating	IP 67
Ambient temperature	- 20°C / +70°C
Service factor	S2: 15mn - S4: 50% (SA 05)
	S2: 15mn - S4: 30% (SA 09)



MECHANICAL FEATURES

Gear box	treated steel pinions
Torque	50 Nm / 90 Nm
Angle of rotation	90° +/- 5°
Declutching	Without
Override control	by key (except for SA 05 S)

Actuator	SA 05 / SA 09			SA 05 S	
Voltage	230V AC	24V AC/DC	12V DC	230V AC	24V AC/DC
Torque (Nm)	50 / 90			50	
Manoeuvring time (s)	17 / 32	10 / 22	11 / 25	100	100
ISO 5211	F03/F05/F07 star 14				

ELECTRICAL FEATURES

Motor protection	Thermal switch	Anti-condensation	5W heater
Limit switches	2 adjustable switches	Electrical connection	2 x P.E. M20x1.5
Auxiliary switches	2 adjustable dry switches		

Actuator	SA 05 / SA 09			SA 05 S	
Voltage	230V AC	24V AC/DC	12V DC	230V AC	24V AC/DC
Power (W)	6 W	15 W	6 W	6 W	6 W
Current (A)	0,23 / 0,25	1,8 / 2,1	3,2 / 3,4	0,23	1,8


Information given as an indication only, and subject to possible modifications

	SECTORIEL S.A. 45 rue du Ruisseau 38290 SAINT QUENTIN-FALLAVIER - FRANCE Telephone: +33 4 74 94 90 70 - Fax: +33 4 74 94 13 95 www.sectoriel.com / Email: sectoriel@sectoriel.fr	Pages	1/6
		Ref.	TDS23010
		Rev.	15
		Date	10/2024

SA 05 - SA 09 ELECTRIC ACTUATOR






CONSTRUCTION

1	Housing	Polyester-coated aluminium
2	Electrical motor	
3	Gear box	Treated steel pinions
4	Cover	Polyester-coated aluminium
5	Position indicator	Polycarbonate plastic
6	Condenser	
7	Handle override	
8	Earthing	
9	Cable inlet	
10	Anti-condensation heater	
11	Terminal box	



DIMENSIONS (mm) AND WEIGHT (kg)

Dimensions (mm)	A	B	C	D	E	Weight (kg)
SA 05 / SA 09	127	170	70	153	80	3.2



Information given as an indication only, and subject to possible modifications

	SECTORIEL S.A. 45 rue du Ruisseau 38290 SAINT QUENTIN-FALLAVIER - FRANCE Telephone: +33 4 74 94 90 70 - Fax: +33 4 74 94 13 95 www.sectoriel.com / Email: sectoriel@sectoriel.fr	Pages	2/6
		Ref.	TDS23010
		Rev.	15
		Date	10/2024

SA 05 - SA 09 ELECTRIC ACTUATOR

WIRING DIAGRAM 230V AC 50Hz/60Hz

1	common	CLS : Close Limit Switch (250VAC 3A) OLS : Open Limit Switch (250VAC 3A) ACLS : Aux Close Limit Switch (250VAC 3A) AOLS : Aux Open Limit Switch (250VAC 3A) TP : Thermal Protector (250VAC 3A) RM : Motor Regulation
2	anti-condensation heater	
3	closing command	
4	opening command	
5	closing auxiliary	
6	closing auxiliary	
7	opening auxiliary	
8	opening auxiliary	

WIRING DIAGRAM 24V AC/DC-12V DC

1	common or +	CLS : Close Limit Switch (250VAC 3A) OLS : Open Limit Switch (250VAC 3A) ACLS : Aux Close Limit Switch (250VAC 3A) AOLS : Aux Open Limit Switch (250VAC 3A) TP : Thermal Protector (250VAC 3A) RM : Motor Regulation
2	closing command	
3	opening command	
4	closing auxiliary	
5	opening auxiliary	
6	auxiliaries common	
7	anti-condensation heater power supply	
8	anti-condensation heater power supply	

OPTIONS

1	SA 05 / SA 09 X: version for ATEX zone
2	SA 05 / SA 09 PIU: version with feedback potentiometer
3	SA 05 / SA 09 CPT: version with position transmitter 4-20 mA
4	SA 05 / SA 09 PCU: version with adjustment card 0-10, 2-10V, 2-20 mA, 4-20 mA
5	SA 05 / SA 09 LCU: version with local control
6	SA 05 / SA 09 SCP: version with super capacitor safety

Information given as an indication only, and subject to possible modifications

	SECTORIEL S.A. 45 rue du Ruisseau 38290 SAINT QUENTIN-FALLAVIER - FRANCE Telephone: +33 4 74 94 90 70 - Fax: +33 4 74 94 13 95 www.sectoriel.com / Email: sectoriel@sectoriel.fr	Pages	3/6
		Ref.	TDS23010
		Rev.	15
		Date	10/2024

SA 05 - SA 09 ELECTRIC ACTUATOR

SPARE PARTS

SA05 Electric actuator	
Gear box	
Printed circuit board	
Electrical motor	
Pinion	
https://www.sectoriel.com/fr/sa05-servomoteur-electrique-aluminium-1-4-tour-50-nm-on-off-ip67.html	

SA09 Electrical actuator	
Gear box	
Printed circuit board	
Electrical motor	
https://www.sectoriel.com/fr/sa09-servomoteur-electrique-aluminium-1-4-tour-90-nm-on-off-ip67.html	

Information given as an indication only, and subject to possible modifications

	SECTORIEL S.A. 45 rue du Ruisseau 38290 SAINT QUENTIN-FALLAVIER - FRANCE Telephone: +33 4 74 94 90 70 - Fax: +33 4 74 94 13 95 www.sectoriel.com / Email: sectoriel@sectoriel.fr	Pages	4/6
		Ref.	TDS23010
		Rev.	15
		Date	10/2024

SA 05 - SA 09 ELECTRIC ACTUATOR

ASSEMBLING AND MAINTENANCE INSTRUCTIONS



SA05 - SA05S - SA09



SA05X - SA09X

1. DESCRIPTION

- 1.1 Electric actuator for motorising 90° turn valves.
- 1.2 The full features of this device are given in sheet FT23010 / FT23310.
- 1.3 Before operating this device, read the present instructions carefully.

2. GUARANTEE

- 2.1 Before any contact with our services, identify the type of actuator.
- 2.2 SECTORIEL actuators have a 12-month guarantee from the delivery date. Parts recognized as defective by an assessment at our facility, will be replaced at our expense. Complaints generated by incorrect use or a modification of the actuator cannot be taken into account.

3. VERIFICATIONS AND ACCEPTANCE

- 3.1 At acceptance, check that:
 - the packaging is in good condition;
 - the actuator is as ordered;
 - the equipment is not damaged.
- 3.2 It is recommended to install the actuator as soon as accepted and not to leave it unused. If the equipment has to be stored, it has to be in a dry place protected from weather.

Information given as an indication only, and subject to possible modifications

	SECTORIEL S.A. 45 rue du Ruisseau 38290 SAINT QUENTIN-FALLAVIER - FRANCE Telephone: +33 4 74 94 90 70 - Fax: +33 4 74 94 13 95 www.sectoriel.com / Email: sectoriel@sectoriel.fr	Pages	5/6
		Ref.	TDS23010
		Rev.	15
		Date	10/2024

SA 05 - SA 09 ELECTRIC ACTUATOR

4. PRECAUTIONS FOR OPERATION


- 4.1 Before installing, make sure that the installation is completely depressurized and brought to ambient temperature.
- 4.2 In a zone classified as explosive, install only model SA05X / SA09X.
- 4.3 The protection class of the actuator is IP67 for indoors or outdoors installation. Do not install this actuator in a marine environment and do not immerse it.
- 4.4 The actuator must not be electrically powered during the installation and maintenance of the valve on the pipework, and of the actuator on the valve
- 4.5 Before proceeding to the electrical connection, check the supply voltage of the actuator.
- 4.6 Do not mount the actuator in series or in parallel with other electrical motors. If need be, use relays.
- 4.7 Do not mount the actuator on valves with higher torque than the nominal torque of the actuator.
- 4.8 The anti-condensation heater must be wired, indoors and outdoors, on special applications.

5. INSTALLATION AND OPERATION

- 5.1 Install the actuator on the valve (already done for units assembled in our workshops)
- 5.2 Perform the electrical wiring as shown in the diagram below.
- 5.3 Adjust the switch stops (already done for units assembled in our workshops).
- 5.4 View the valve's movement using the indicator light on the cover.
- 5.5 SA05 / SA09 and SA05X / SA09X actuator: to actuate the handle override, first disconnect the electrical power supply, then turn the hollow hex-head screw with an Allen key.
No handle override for SA05S.
- 5.6 SA05X actuator: the electrical connection must be carried out using an ATEX approved cable gland (CG) CG M20x1.5 which corresponds to the same operation zones as SA05X / SA09X.
SA05X has 2 connections M20x1.5. If using only one CG ATEX cable gland, the 2nd connection must be provided with an ATEX-approved plug which corresponds to the same operation zones as SA05X / SA09X.
CG and ATEX plug are not provided as standard. Option when ordering.

6. SWITCH SETTING

- 6.1 The cams are attached to the drive stem.
- 6.2 Clockwise rotation = valve closing. The micro-switch stops the actuator.
- 6.3 Anti-clockwise rotation = valve opening. The micro-switch stops the actuator.



Information given as an indication only, and subject to possible modifications

	SECTORIEL S.A. 45 rue du Ruisseau 38290 SAINT QUENTIN-FALLAVIER - FRANCE Telephone: +33 4 74 94 90 70 - Fax: +33 4 74 94 13 95 www.sectoriel.com / Email: sectoriel@sectoriel.fr	Pages	6/6
		Ref.	TDS23010
		Rev.	15
		Date	10/2024

SA 05-X - SA 09-X ELECTRIC ACTUATOR

FEATURES

SA05-X - SA09-X electric actuators are intended for motorising 1/4 turn valves in hazardous areas. The torque are 50 Nm (SA05-X) and 90 Nm (SA09-X). The protection mode is a "d" explosion-proof. With a compact, robust construction and IP67 epoxy-coated aluminium housing, the SA05-X and SA09-X actuator are especially well suited for motorising ball valves and butterfly valves installed in hazardous areas. The SA05-X and SA09-X are equipped with a key-operated hand control and a 3D visual position indicator. It is compliant with the EN 15714-2 standard.

AVAILABLE MODELS

Supply voltages: 230V AC (50-60Hz), 24V AC/DC.

LIMITS OF USE

IP Code	IP 67
Ambient temperature	- 20°C / +55°C
Service factor	S2 : 15mn - S4 : 50%



ATEX APPROVAL

Protection mode	"d" according to the EN 60079-1 standard
Category of material	2
Operation zones	1G and 2G
Marking	II 2 G Ex d IIB T4 (ON KEMA no. 0344)



MECHANICAL FEATURES

Gear box	treated steel pinions
Torque	50 Nm (SA05-X) / 90 Nm (SA09-X)
Angle of rotation	90° +/- 5°
Declutching	Without
Override control	By key

Actuator	SA05-X (50Hz)		SA05-X (60Hz)	SA09-X (50Hz)	SA09-X (50Hz)	SA09-X (60Hz)
Voltage	230V AC	24V AC/DC	230V AC	230V AC	24V AC/DC	230V AC
Torque (Nm)	50		50	90		90
Manoeuvring time (s)	17	10	14	36	17	30
ISO 5211	F03/F05/F07 star 14					

Information given as an indication only, and subject to possible modifications



SECTORIEL S.A.
45 rue du Ruisseau
38290 SAINT QUENTIN-FALLAVIER - FRANCE
Telephone: +33 4 74 94 90 70 - Fax: +33 4 74 94 13 95
www.sectoriel.com / Email : sectoriel@sectoriel.fr

Pages	1/7
Ref.	TDS23310
Rev.	09
Date	10/2024

SA 05-X - SA 09-X ELECTRIC ACTUATOR


ELECTRICAL FEATURES

Motor protection	Thermal switch	Anti-condensation	5W heater
Limit switches	2 adjustable switches	Electrical connection	2 x C.G. M20x1.5 ATEX (NOT SUPPLIED on option)
Auxiliary switches	2 adjustable dry switches		

Actuator	SA05 X		SA09 X	
Voltage	230V AC	24V AC/DC	230V AC	24V AC/DC
Power (W)	6 W	15 W	6 W	15 W
Current (A)	0.23	1.8	0.19	1.8

CONSTRUCTION

1	Housing	Polyester-coated aluminium
2	Electrical motor	
3	Gear box	Treated steel pinions
4	Cover	Polyester-coated aluminium
5	Position indicator	Polycarbonate plastic
6	Condenser	
7	Handle override	
8	Earthing	
9	Cable inlet	
10	Anti-condensation heater	
11	Terminal box	
12	Indicator light	Toughened glass




Information given as an indication only, and subject to possible modifications

	SECTORIEL S.A. 45 rue du Ruisseau 38290 SAINT QUENTIN-FALLAVIER - FRANCE Telephone: +33 4 74 94 90 70 - Fax: +33 4 74 94 13 95 www.sectoriel.com / Email : sectoriel@sectoriel.fr	Pages	2/7
		Ref.	TDS23310
		Rev.	09
		Date	10/2024

SA 05-X - SA 09-X ELECTRIC ACTUATOR

DIMENSIONS (mm) AND WEIGHT (kg)

Dimensions (mm)	A	B	C	D	E	F	Weight (kg)
SA05-X / SA09-X	147	73	193	83	100	199	5



Information given as an indication only, and subject to possible modifications

	SECTORIEL S.A. 45 rue du Ruisseau 38290 SAINT QUENTIN-FALLAVIER - FRANCE Telephone: +33 4 74 94 90 70 - Fax: +33 4 74 94 13 95 www.sectoriel.com / Email : sectoriel@sectoriel.fr	Pages	3/7
		Ref.	TDS23310
		Rev.	09
		Date	10/2024

SA 05-X - SA 09-X ELECTRIC ACTUATOR

WIRING DIAGRAM 230V AC 50Hz/60Hz

1	common	CLS : Close Limit Switch (250VAC 3A) OLS : Open Limit Switch (250VAC 3A) ACLS : Aux Close Limit Switch (250VAC 3A) AOLS : Aux Open Limit Switch (250VAC 3A) TP : Thermal Protector (250VAC 3A) RM : Motor Regulation
2	anti-condensation heater	
3	closing command	
4	opening command	
5	closing auxiliary	
6	closing auxiliary	
7	opening auxiliary	
8	opening auxiliary	

WIRING DIAGRAM 24V AC/DC

1	common or +	CLS : Close Limit Switch (250VAC 3A) OLS : Open Limit Switch (250VAC 3A) ACLS : Aux Close Limit Switch (250VAC 3A) AOLS : Aux Open Limit Switch (250VAC 3A) TP : Thermal Protector (250VAC 3A) RM : Motor Regulation
2	closing command	
3	opening command	
4	closing auxiliary	
5	opening auxiliary	
6	auxiliaries common	
7	anti-condensation heater power supply	
8	anti-condensation heater power supply	

OPTIONS

1	SA 05 X / SA 09 PIU : version with feedback potentiometer
2	SA 05 X / SA 09 X CPT : version with position transmitter 4-20 mA
3	SA 05 X / SA 09 PCU : version with adjustment card 0-10, 2-10V, 2-20 mA, 4-20 mA

Information given as an indication only, and subject to possible modifications

	SECTORIEL S.A. 45 rue du Ruisseau 38290 SAINT QUENTIN-FALLAVIER - FRANCE Telephone: +33 4 74 94 90 70 - Fax: +33 4 74 94 13 95 www.sectoriel.com / Email : sectoriel@sectoriel.fr	Pages	4/7
		Ref.	TDS23310
		Rev.	09
		Date	10/2024

SA 05-X - SA 09-X ELECTRIC ACTUATOR

SPARE PARTS

SA05-X / SA09-X Electric actuator	
Gear box	
Printed circuit board	
Pinion (SA05-X)	
Electrical motor	
https://www.sectoriel.com/fr/sa05x-servomoteur-electrique-atex-1-4-tour-50-nm-on-off-ip67.html	

Information given as an indication only, and subject to possible modifications

	SECTORIEL S.A. 45 rue du Ruisseau 38290 SAINT QUENTIN-FALLAVIER - FRANCE Telephone: +33 4 74 94 90 70 - Fax: +33 4 74 94 13 95 www.sectoriel.com / Email : sectoriel@sectoriel.fr	Pages	5/7
		Ref.	TDS23310
		Rev.	09
		Date	10/2024

SA 05-X - SA 09-X ELECTRIC ACTUATOR

ASSEMBLING AND MAINTENANCE INSTRUCTIONS



SA05 - SA05S - SA09



SA05X - SA09X

1. DESCRIPTION

- 1.1 Electric actuator for motorising 90° turn valves.
- 1.2 The full features of this device are given in sheet FT23010 / FT23310.
- 1.3 Before operating this device, read the present instructions carefully.

2. GUARANTEE

- 2.1 Before any contact with our services, identify the type of actuator.
- 2.2 SECTORIEL actuators have a 12-month guarantee from the delivery date. Parts recognized as defective by an assessment at our facility, will be replaced at our expense. Complaints generated by incorrect use or a modification of the actuator cannot be taken into account.

3. VERIFICATIONS AND ACCEPTANCE

- 3.1 At acceptance, check that:
 - the packaging is in good condition;
 - the actuator is as ordered;
 - the equipment is not damaged.
- 3.2 It is recommended to install the actuator as soon as accepted and not to leave it unused. If the equipment has to be stored, it has to be in a dry place protected from weather.

Information given as an indication only, and subject to possible modifications

	SECTORIEL S.A. 45 rue du Ruisseau 38290 SAINT QUENTIN-FALLAVIER - FRANCE Telephone: +33 4 74 94 90 70 - Fax: +33 4 74 94 13 95 www.sectoriel.com / Email : sectoriel@sectoriel.fr	Pages	6/7
		Ref.	TDS23310
		Rev.	09
		Date	10/2024

SA 05-X - SA 09-X ELECTRIC ACTUATOR

4. PRECAUTIONS FOR OPERATION


- 4.1 Before installing, make sure that the installation is completely depressurized and brought to ambient temperature.
- 4.2 In a zone classified as explosive, install only model SA05X / SA09X.
- 4.3 The protection class of the actuator is IP67 for indoors or outdoors installation. Do not install this actuator in a marine environment and do not immerse it.
- 4.4 The actuator must not be electrically powered during the installation and maintenance of the valve on the pipework, and of the actuator on the valve
- 4.5 Before proceeding to the electrical connection, check the supply voltage of the actuator.
- 4.6 Do not mount the actuator in series or in parallel with other electrical motors. If need be, use relays.
- 4.7 Do not mount the actuator on valves with higher torque than the nominal torque of the actuator.
- 4.8 The anti-condensation heater must be wired, indoors and outdoors, on special applications.

5. INSTALLATION AND OPERATION

- 5.1 Install the actuator on the valve (already done for units assembled in our workshops)
- 5.2 Perform the electrical wiring as shown in the diagram below.
- 5.3 Adjust the switch stops (already done for units assembled in our workshops).
- 5.4 View the valve's movement using the indicator light on the cover.
- 5.5 SA05 / SA09 and SA05X / SA09X actuator: to actuate the handle override, first disconnect the electrical power supply, then turn the hollow hex-head screw with an Allen key.
No handle override for SA05S.
- 5.6 SA05X actuator: the electrical connection must be carried out using an ATEX approved cable gland (CG) CG M20x1.5 which corresponds to the same operation zones as SA05X / SA09X.
SA05X has 2 connections M20x1.5. If using only one CG ATEX cable gland, the 2nd connection must be provided with an ATEX-approved plug which corresponds to the same operation zones as SA05X / SA09X.
CG and ATEX plug are not provided as standard. Option when ordering.

6. SWITCH SETTING

- 6.1 The cams are attached to the drive stem.
- 6.2 Clockwise rotation = valve closing. The micro-switch stops the actuator.
- 6.3 Anti-clockwise rotation = valve opening. The micro-switch stops the actuator.



Information given as an indication only, and subject to possible modifications

	SECTORIEL S.A. 45 rue du Ruisseau 38290 SAINT QUENTIN-FALLAVIER - FRANCE Telephone: +33 4 74 94 90 70 - Fax: +33 4 74 94 13 95 www.sectoriel.com / Email : sectoriel@sectoriel.fr	Pages	7/7
		Ref.	TDS23310
		Rev.	09
		Date	10/2024